



EDINBURG CISD

PURCHASING DEPARTMENT

411 N. 8th Ave., Edinburg, TX 78541
(956) 289-2311, (956) 383-7687

DOMINGA "MINGA" VELA, President
CARMEN GONZÁLEZ, Vice President
OSCAR SALINAS, Secretary
LUIS ALAMIA, Member
MIGUEL "MIKE" FARIAS, Member
LETICIA "LETTY" GARCIA, Member
XAVIER SALINAS, Member

Dr. Mario H. Salinas, Superintendent

ADDENDUM 2

CSP 22-81

ECONOMEDES HIGH SCHOOL HEATING & AIR CONDITION (HVAC) IMPROVEMENTS FUNDED THROUGH THE ELEMENTARY & SECONDARY SCHOOLS EMERGENCY RELIEF (ESSER) FUNDS

May 19, 2022

I. INSTRUCTIONS:

- A. The following update to the specification shall be made insofar as the specifications, this addendum shall govern.
- B. It is imperative that this addendum be inserted INTO set of specifications. Acknowledge receipt of this addendum by inserting and including as part of the RFQ specifications.

II. SEE ADDENDUM BELOW:

PLEASE SEE ATTACHED

Respectfully Submitted,

Amaro Tijerina
Director of Purchasing

(Signature of authorized officer) Date

Company Name

Nondiscrimination Statement

It is the policy of Edinburg CISD not to discriminate on the basis of gender, age, handicap, religion, race, color, or national origin in its educational programs.

Es poliza del Distrito Escolar de Edinburg el no discriminar por razones con base en genero, edad, religion, raza, color origen nacional, ni discapacidad dentro de sus programas educacionales.

ADDENDUM 2

TO:	Prospective Bidders	DATE:	May 19, 2022
FROM:	Gabriel Hinojosa, PE, LEED AP Sigma HN Engineers, PLLC 701 S 15th St McAllen, TX 78501	PROJECT:	Edinburg CISD ESSER HVAC Improvements CSP 22-81 Economedes High School CPS 22-82 Longoria Middle School CSP 22-83 Esparza Elementary CSP 22-84 Escandon Elementary

This Addendum forms a part of the Contract Documents and modifies the Bidding Documents dated May 23, 2022, with amendments and questions from RFI's noted below.

CSP 22-81: J. Economedes High School

- VAC asked: General Note "F" on all the M-Sheets starting with M-1.0 states "clean all return air grilles and supply diffusers being served by chilled water air handlers." How are we to determine the number of air devices that need to be cleaned? At this time no air devices are shown on the documents.*

Contractor will not be required to clean all return air grilles and supply diffusers served by the chilled water air handlers. Disregard this note.

- VAC asked: Who is the school district's roofing manufacturer holding the warranty on the existing room at J. Economedes High School?*

This question was answered in Addendum #1.

