



EDINBURG CISD

PURCHASING DEPARTMENT

411 N. 8th Ave., Edinburg, TX 78541

(956) 289-2311, (956) 383-7687

DOMINGA "MINGA" VELA, President
CARMEN GONZÁLEZ, Vice President
OSCAR SALINAS, Secretary
LUIS ALAMIA, Member
MIGUEL "MIKE" FARIAS, Member
LETICIA "LETTY" GARCIA, Member
XAVIER SALINAS, Member

Dr. Mario H. Salinas, Superintendent

ADDENDUM 3

CSP 22-133

Barrientes Middle School Heating & Air Condition (HVAC) Improvements Funded through the Elementary & Secondary Emergency Relief (ESSER) Funds September 14, 2022

I. INSTRUCTIONS:

- A. The following changes, omissions or alterations to the specification and drawings shall be made insofar as the specifications and drawings are inconsistent with following, this addendum shall govern.
- B. Acknowledge receipt of this addendum by inserting its number and date of issue in the place provided for same in the proposal. This addendum forms a part of the Contract Documents.
- C. It is imperative that this addendum be inserted INTO set of specifications.

II. SEE ADDENDUM BELOW:

See attached.

Respectfully Submitted,

Amaro Tijerina
Director of Purchasing

(Signature of authorized officer)

Date

Company Name

Nondiscrimination Statement

It is the policy of Edinburg CISD not to discriminate on the basis of gender, age, handicap, religion, race, color, or national origin in its educational programs.
Es poliza del Distrito Escolar de Edinburg el no discriminar por razones con base en genero, edad, religion, raza, color origen nacional, ni discapacidad dentro de sus programas educacionales.

ADDENDUM #3
ECISD ESSER HVAC IMPROVEMENTS
BARRIENTES MIDDLE SCHOOL
9/13/2022

The following items shall become a part of the contract documents. Refer to full or partial sheets referenced and make changes noted. Bidders are responsible for reading all sections of the addendum. The Addendum consists of the following:

Request For Information (the following items are questions and responses as requested from the bidders)

- Item 1 Question: Can you please provide clarification if the BAS system being requested as part of this bid is for the replacement of the entire school campus or solely for the HVAC mechanical equipment being changed out? Our understanding is that the equipment not being replaced is to remain on the existing Trane automation system.
Response: The BAS system is for the replacement of the mechanical equipment being changed out. The equipment not being replaced is to remain on the existing Trane automation system.



Luis Javier Pena

09.13.2022



MECHANICAL, ELECTRICAL, PLUMBING ENGINEERS
600 E. BEAUMONT AVE. SUITE 2 McALLEN, TX 78501 (956) 664-2727
TEXAS BOARD OF PROFESSIONAL ENGINEERS REGISTRATION # F-9748